

# LESEN PENSIJILAN BARANGAN

## *Product Certification Licence*



**SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada**  
*SIRIM QAS International Sdn. Bhd. hereby grants to*

**MAXGUARD SWITCHGEAR SDN. BHD.**  
**NO. 8, JALAN ANGERIK MOKARA 31/47**  
**KOTA KEMUNING, SEKSYEN 31**  
**40460 SHAH ALAM**  
**SELANGOR, MALAYSIA**

**Lesen untuk menggunakan Tanda Pensijilan di atas barangan**  
*a licence to use the Certification Mark on*

**MINIATURE CIRCUIT-BREAKERS (MCBs)**

**Please refer to detail in the SCHEDULE**

**sebagai mematuhi keperluan**  
*as complying with*

**MS IEC 60898-1 : 2007**



**Nur Fadhilah binti Muhammad**  
Ketua Pegawai Eksekutif  
*Chief Executive Officer*  
SIRIM QAS International Sdn. Bhd.



# SCHEDULE

## MAXGUARD SWITCHGEAR SDN. BHD.



Trade Mark : MAXGUARD  
Model : MB63-1  
Rating : 240/415V, 50/60HZ, C1, C2, C3, C4, C6, C10, C16, C20, C25, C32, C40, C50, C63, 6000A  
Type : TYPE C, SINGLE POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : MB63-1  
Rating : 415V, 50/60HZ, C1, C2, C3, C4, C6, C10, C16, C20, C25, C32, C40, C50, C63, 6000A  
Type : TYPE C, TWO-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : MB63-1  
Rating : 415V, 50/60HZ, B1, B2, B3, B4, B6, B10, B16, B20, B25, B32, B40, B50, B63, 6000A  
Type : TYPE B, THREE-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : MB63-1  
Rating : 415V, 50/60HZ, C1, C2, C3, C4, C6, C10, C16, C20, C25, C32, C40, C50, C63, 6000A  
Type : TYPE C, THREE-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : F2  
Rating : 415V, 50/60HZ, C1, C2, C3, C4, C6, C10, C16, C20, C25, C32, C40, C50, C63, 10000A  
Type : TYPE C, TWO-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

# SCHEDULE

## MAXGUARD SWITCHGEAR SDN. BHD.



Trade Mark : MAXGUARD  
Model : F2  
Rating : 415V, 50/60HZ, D1, D2, D3, D4, D6, D10, D16, D20, D25, D32, D40, D50, D63,  
10000A  
Type : TYPE D, TWO-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : F2  
Rating : 415V, 50/60HZ, B1, B2, B3, B4, B6, B10, B16, B20, B25, B32, B40, B50, B63,  
10000A  
Type : TYPE B, THREE-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : F2  
Rating : 415V, 50/60HZ, D1, D2, D3, D4, D6, D10, D16, D20, D25, D32, D40, D50, D63,  
10000A  
Type : TYPE D, THREE-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : F2  
Rating : 415V, 50/60HZ, B1, B2, B3, B4, B6, B10, B16, B20, B25, B32, B40, B50, B63,  
10000A  
Type : TYPE B, FOUR-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : MB63-1  
Rating : 240/415V, 50/60HZ, B1, B2, B3, B4, B6, B10, B16, B20, B25, B32, B40, B50, B63,  
6000A  
Type : TYPE B, SINGLE POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

# SCHEDULE

## MAXGUARD SWITCHGEAR SDN. BHD.



Trade Mark : MAXGUARD  
Model : F2  
Rating : 415V, 50/60HZ, C1, C2, C3, C4, C6, C10, C16, C20, C25, C32, C40, C50, C63,  
10000A  
Type : TYPE C, FOUR-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : F2  
Rating : 415V, 50/60HZ, D1, D2, D3, D4, D6, D10, D16, D20, D25, D32, D40, D50, D63,  
10000A  
Type : TYPE D, FOUR-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : F2  
Rating : 240/415V, 50/60HZ, B1, B2, B3, B4, B6, B10, B16, B20, B25, B32, B40, B50, B63,  
10000A  
Type : TYPE B, SINGLE POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : F2  
Rating : 240/415V, 50/60HZ, C1, C2, C3, C4, C6, C10, C16, C20, C25, C32, C40, C50, C63,  
10000A  
Type : TYPE C, SINGLE POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : F2  
Rating : 240/415V, 50/60HZ, D1, D2, D3, D4, D6, D10, D16, D20, D25, D32, D40, D50, D63,  
10000A  
Type : TYPE D, SINGLE POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

# SCHEDULE

## MAXGUARD SWITCHGEAR SDN. BHD.



Trade Mark : MAXGUARD  
Model : F2  
Rating : 415V, 50/60HZ, B1, B2, B3, B4, B6, B10, B16, B20, B25, B32, B40, B50, B63, 10000A  
Type : TYPE B, TWO-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : MB63-1  
Rating : 415V, 50/60HZ, B1, B2, B3, B4, B6, B10, B16, B20, B25, B32, B40, B50, B63, 6000A  
Type : TYPE B, TWO-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : MB63-1  
Rating : 415V, 50/60HZ, B1, B2, B3, B4, B6, B10, B16, B20, B25, B32, B40, B50, B63, 6000A  
Type : TYPE B, FOUR-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : MB63-1  
Rating : 415V, 50/60HZ, C1, C2, C3, C4, C6, C10, C16, C20, C25, C32, C40, C50, C63, 6000A  
Type : TYPE C, FOUR-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

Trade Mark : MAXGUARD  
Model : F2  
Rating : 415V, 50/60HZ, C1, C2, C3, C4, C6, C10, C16, C20, C25, C32, C40, C50, C63, 10000A  
Type : TYPE C, THREE-POLE  
Full type test conducted in accordance to IEC 60898 - 1: 2015.

SIRIM QAS International Sdn. Bhd.  
(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri  
Seksyen 2, Peti Surat 7035  
40700 Shah Alam  
Selangor Darul Ehsan  
MALAYSIA.

Tel : 603-5544 6000  
Emel : cserviceqas@sirim.my

<https://www.sirim-qas.com.my>  
<https://www.malaysiancertified.com.my>

**Tarikh Mula Pensijilan : 14 September 2006**

*Certified Since*

**Sah Sehingga : 14 September 2025**

*Valid Until*

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.  
*This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.*

**Tarikh Dikeluarkan : 08 August 2024**

*Issue Date*

**No Siri : 101190**

*Serial No*

# SCHEDULE

MAXGUARD SWITCHGEAR SDN. BHD.

**Factory Name and Location :**  
**JOVEAN & ROGY ELECTRICAL HOLDING CO. LTD.,**  
**132, XINGUANG AVENUE,**  
**XINGUANG INDUSTRIAL ZONE,**  
**LIUSHI**  
**325604 WENZHOU**  
**ZHEJIANG, CHINA**



SIRIM

---

*End of page*

---