

LESEN PENSIJILAN BARANGAN

Product Certification Licence



SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
SIRIM QAS International Sdn. Bhd. hereby grants to

MAXGUARD SWITCHGEAR SDN. BHD.
NO. 8, JALAN ANGERIK MOKARA 31/47,
KOTA KEMUNING
40460 SHAH ALAM
SELANGOR, MALAYSIA

Lesen untuk menggunakan Tanda Pensijilan di atas barangan
a licence to use the Certification Mark on

RESIDUAL CURRENT OPERATED CIRCUIT-BREAKERS (RCCBs)

Please refer to detail in the SCHEDULE

sebagai mematuhi keperluan
as complying with

IEC 61008-2-1 : 1990
IEC 61008-1 : 2013



Ts. Md. Adha bin Katni @ Rahmat
Ketua Pegawai Eksekutif
Chief Executive Officer
SIRIM QAS International Sdn. Bhd.



SCHEDULE

MAXGUARD SWITCHGEAR SDN. BHD.



SIRIM

Trade Mark : MAXGUARD
Model : ML63-1, TYPE A, 4P, 40A/30mA
Rating : 415V~, 50/60Hz, 40A/30mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE A, 4P, 40A/100mA
Rating : 415V~, 50/60Hz, 40A/100mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE A, 4P, 63A/30mA
Rating : 415V~, 50/60Hz, 63A/30mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE A, 4P, 63A/100mA
Rating : 415V~, 50/60Hz, 63A/100mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE A, 2P, 63A/30mA
Rating : 240V~, 50/60Hz, 63A/30mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE A, 2P, 63A/100mA
Rating : 240V~, 50/60Hz, 63A/100mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE AC, 2P, 40A/100mA
Rating : 240V~, 50/60Hz, 40A/100mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE A, 2P, 40A/30mA
Rating : 240V~, 50/60Hz, 40A/30mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

SIRIM QAS International Sdn. Bhd.
((No. Syarikat 199601037981(410334-X)))

1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 603-5544 6000
Emel : cserviceqas@sirim.my

Tarikh Mula Pensijilan : 07 August 2006

Certified Since

Sah Sehingga : 07 August 2027

Valid Until

Tarikh Dikeluarkan : 09 July 2026

Issue Date

No Siri : 129923

Serial No

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.

SCHEDULE

MAXGUARD SWITCHGEAR SDN. BHD.



SIRIM

Trade Mark : MAXGUARD
Model : ML 63-1 TYPE A, 2P, 25A/10mA
Rating : 240V~, 50/60Hz, 25A/10mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE AC, 4P, 40A/30mA
Rating : 415V~, 50/60Hz, 40A/30mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE AC, 4P, 40A/100mA
Rating : 415V~, 50/60Hz, 40A/100mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE AC, 4P, 63A/30mA
Rating : 415V~, 50/60Hz, 63A/30mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE AC, 4P, 63A/100mA
Rating : 415V~, 50/60Hz, 63A/100mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE AC, 2P, 25A/10mA
Rating : 240V~, 50/60Hz, 25A/10mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE AC, 2P, 63A/30mA
Rating : 240V~, 50/60Hz, 63A/30mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE AC, 2P, 63A/100mA
Rating : 240V~, 50/60Hz, 63A/100mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

SIRIM QAS International Sdn. Bhd.
((No. Syarikat 199601037981(410334-X)))

1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 603-5544 6000
Emel : cserviceqas@sirim.my

www.sirim-qas.com.my
https://www.malaysiancertified.com.my

Tarikh Mula Pensijilan : 07 August 2006

Certified Since

Sah Sehingga : 07 August 2027

Valid Until

Tarikh Dikeluarkan : 09 July 2026

Issue Date

No Siri : 129923

Serial No

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.

SCHEDULE

MAXGUARD SWITCHGEAR SDN. BHD.



SIRIM

Trade Mark : MAXGUARD
Model : ML63-1, TYPE A, 2P, 40A/100mA
Rating : 240V~, 50/60Hz, 40A/100mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

Trade Mark : MAXGUARD
Model : ML63-1, TYPE AC, 2P, 40A/30mA
Rating : 240V~, 50/60Hz, 40A/30mA, 10000A
Tested to IEC 61008-1: 2010 + A1: 2012 + A2: 2013 & IEC 61008-2-1: 1990

SIRIM QAS International Sdn. Bhd.
((No. Syarikat 199601037981(410334-X)))

1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 603-5544 6000
Emel : cserviceqas@sirim.my

www.sirim-qas.com.my
<https://www.malaysiancertified.com.my>

Tarikh Mula Pensijilan : 07 August 2006

Certified Since

Sah Sehingga : 07 August 2027

Valid Until

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.

Tarikh Dikeluarkan : 09 July 2026

Issue Date

No Siri : 129923

Serial No