

LESEN PENSIJILAN BARANGAN

Product Certification Licence



SIRIM

SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
SIRIM QAS International Sdn. Bhd. hereby grants to

MAXGUARD SWITCHGEAR SDN. BHD.
NO. 8, JALAN ANGERIK MOKARA 31/47,
KOTA KEMUNING
40460 SHAH ALAM
SELANGOR, MALAYSIA

Lesen untuk menggunakan Tanda Pensijilan di atas barangan
a licence to use the Certification Mark on

FUSE COMBINATION UNITS

Please refer to detail in the SCHEDULE

sebagai mematuhi keperluan
as complying with

IEC 60947-1 : 2007
IEC 60947-3 : 2008



Ts. Md. Adha bin Katni @ Rahmat
Ketua Pegawai Eksekutif
Chief Executive Officer
SIRIM QAS International Sdn. Bhd.



SCHEDULE

MAXGUARD SWITCHGEAR SDN. BHD.



SIRIM

Trade Mark : MAXGUARD
Model : SF63 (1P+N, 32A)
Rating : 240V, 50/60HZ, 32A, 1P+N, 10KA
Full type test conducted in accordance to IEC 60947-3:2020 (ED.4) IEC 60947-1:2020

Trade Mark : MAXGUARD
Model : SF32 (1P+N, 32A)
Rating : 240V, 50/60HZ, 32A, 1P+N, 10KA
Full type test conducted in accordance to IEC 60947-3:2020 (ED.4) IEC 60947-1:2020

Trade Mark : MAXGUARD
Model : SF63 (1P, 32A)
Rating : 240V, 50/60HZ, 32A, 1P, 10KA
Full type test conducted in accordance to IEC 60947-3:2020 (ED.4) IEC 60947-1:2020

Trade Mark : MAXGUARD
Model : SF 63 (1P+N, 63A)
Rating : 240V, 50/60HZ, 63A, 1P+N, 10KA
Full type test conducted in accordance to IEC 60947-3:2020 (ED.4) IEC 60947-1:2020

Trade Mark : MAXGUARD
Model : SF63 (3P, 32A)
Rating : 415V, 50/60HZ, 32A, 3P, 10KA
Full type test conducted in accordance to IEC 60947-3:2020 (ED.4) IEC 60947-1:2020

Trade Mark : MAXGUARD
Model : SF63 (3P+N, 32A)
Rating : 415V, 50/60HZ, 32A, 3P+N, 10KA
Full type test conducted in accordance to IEC 60947-3:2020 (ED.4) IEC 60947-1:2020

Trade Mark : MAXGUARD
Model : SF63 (1P, 63A)
Rating : 240V, 50/60HZ, 63A, 1P, 10KA
Full type test conducted in accordance to IEC 60947-3:2020 (ED.4) IEC 60947-1:2020

Trade Mark : MAXGUARD
Model : SF63 (3P+N, 63A)
Rating : 415V, 50/60HZ, 63A, 3P+N, 10KA
Full type test conducted in accordance to IEC 60947-3:2020 (ED.4) IEC 60947-1:2020

SIRIM QAS International Sdn. Bhd.
(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 603-5544 6000
Emel : cserviceqas@sirim.my

<https://www.sirim-qas.com.my>
<https://www.malaysiancertified.com.my>

Tarikh Mula Pensijilan : 29 October 2010

Certified Since

Sah Sehingga : 29 October 2026

Valid Until

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.

Tarikh Dikeluarkan : 16 October 2025

Issue Date

No Siri : 118038

Serial No

SCHEDULE

MAXGUARD SWITCHGEAR SDN. BHD.

Trade Mark : MAXGUARD
Model : SF63 (3P, 63A)
Rating : 415V, 50/60HZ, 63A, 3P, 10KA
Full type test conducted in accordance to IEC 60947-3:2020 (ED.4) IEC 60947-1:2020



SIRIM

End of page

SIRIM QAS International Sdn. Bhd.
(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 603-5544 6000
Emel : cserviceqas@sirim.my

<https://www.sirim-qas.com.my>
<https://www.malaysiancertified.com.my>

Tarikh Mula Pensijilan : 29 October 2010

Certified Since

Sah Sehingga : 29 October 2026

Valid Until

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.

Tarikh Dikeluarkan : 16 October 2025

Issue Date

No Siri : 118038

Serial No